



STANDARDSMARK LICENCE

SAI Global hereby grants:

Steel Mains Proprietary Limited

ABN 73 004 843 056

Lot 6, Leath Road, Naval Base, WA 6167, Australia

StandardsMark Licence

Manufactured to:

AS 1579-2001 - Arc-welded steel pipes and fittings for water and waste-water

"the StandardsMark Licensee" the right to use the STANDARDSMARK as shown below only in respect of the goods described and detailed in the Schedule which are produced by the Licensee or on behalf of the Licensee* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the STANDARDSMARK and the Terms and Conditions for certification and licence. The Licensee covenants to comply with all the Rules and Terms and Conditions.

Licence No: SMK40658

Issued : 19 April 2017

Expires : 18 April 2022

Originally Certified : 19 April 2017

Current Certification : 19 April 2017

Nicole Grantham
General Manager SAI Global Certification Services



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com, for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

SAI Global hereby grants:

Steel Mains Proprietary Limited

Lot 6, Leath Road, Naval Base, WA 6167, Australia

StandardsMark Licence

Manufactured to:

AS 1579-2001 - Arc-welded steel pipes and fittings for water and waste-water

Model identification of the goods on which the STANDARDSMARK may be used:

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	700	711	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	750	762	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	600	610	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	450	457	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	500	508	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1200	1219	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1400	1422	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1000	1016	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	800	813	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017
OD 460-OD1422, Plain End	Pipe, Plain End or Plain End with Bevel Joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	900	914	4.5 - 16.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Plain End or Plain End with Bevel Joints	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	900	914	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	800	813	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1000	1016	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1400	1422	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1200	1219	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	500	508	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	450	457	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	600	610	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	750	762	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, RRJ	Pipe, Elastomeric Ring Joint	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	700	711	4.5 - 12.0	0 - 4.25	Fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Elastomeric Ring Joint	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastomeric Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1000	1016	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastomeric Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	900	914	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastomeric Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1400	1422	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastomeric Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1200	1219	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	800	813	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	600	610	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	500	508	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	750	762	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	700	711	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SLJ-Type 1	Pipe, Welded Joint with Elastic Ring Enhancement	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	450	457	4.5 - 10.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Sintalock Type 1	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	600	610	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	700	711	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	500	508	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	450	457	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1000	1016	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1200	1219	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	1400	1422	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Material Designation	Nominal Size (DN)	Outside Diameter (mm)	Wall Thickness (mm)	Rated Pressure (MPa)	Coating Designation	Lining Designation	Joint Designation	Date Endorsed
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	900	914	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	750	762	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017
OD 460-OD1422, SSJ	Pipe, Spherical Slip-in-joints	Steel Mains Sintakote	Steel Pipe 6m(min) - 12.3m(max)	Spiral Steel Pipe	Steel	800	813	4.5 - 12.0	0 - 6.80	Uncoated, or fusion bonded medium density polyethylene or paint	Unlined, Cement mortar, or sealcoated cement mortar or fusion bonded medium density polyethylene or paint	Spherical slip-in-Joints	12 Apr 2017

End of Record

Licence No: SMK40658

Issued Date: 19 April 2017

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.